





**TEST REPORT**

Test Report No.:	TR120200903001	Page 1 of 5	
		Issue Date: 03/09/2020	
Customer/Manufacture Name:	System Level Solutions (India) Pvt. Ltd. Plot No. 32, Zone D-4, Phase-1, G.I.D.C. Estate, Vithal Udyognagar-388121, Gujarat, India.		
Sample/Item Description:	Said to be "Micro Inverter, Single Phase, grid tied, 1400W output power, utility interactive inverter with integrated GFDI, Brand: System Level Solutions, Trademark: System Level Solutions"		
Sample/Item Condition:	Fit for testing		
Identification:	Model Name: MSI1500	Serial No.:	1114A4050046
		Sample Code:	N/A
Sample Deposited/Collected by:	Customer		
Customer Reference no.	Nil	Date:	20/08/2020
Job Order No.:	BTH-R1/EL/200821/1	Date of receipt:	21/08/2020
Date(s) of performance of tests	21/08/2020 to 03/09/2020		
Test Location:	At Lab		
Laboratory Name and Address:	<b>BHARAT TEST HOUSE PVT. LTD.</b> 1474, HSIIDC Indl. Estate, Rai, Distt. Sonapat-131001 Haryana.		
Test specification(s):	Protocol followed as per IEC 61683:1999		
General Environmental Conditions:	Temperature: 25±2°C, Relative humidity: 65±5%RH, Air Pressure: 75kPa to 106kPa		
	 Scan this QR Code to verify the Report		
Result:	The sample confirms the relevant test specification as per below report.		
Supplementary Information:	- Deviation from the test methods as prescribed in relevant Specification/Work Instructions: Nil. - The information supplied by the customer may affect the validity of results reported as per standard requirement.		
Abbreviations:	N/A		
Remarks:	1. The report has been generated and verified digitally.		
	<i>This report is related to the sample submitted.</i>		

Tested by:	Approved by:	Issued by:
		
T. Gautam	P. Dinesh Babu	P. Dinesh Babu
Testing Engineer	TM	TM
Date: 03/09/2020	Date: 03/09/2020	Date: 03/09/2020

BTHPL/7.2/01

**BHARAT TEST HOUSE PVT. LTD.**

 1474, HSIIDC Industrial Estate, Rai, Distt-Sonapat, Haryana-131001  
 Tel: 0130-2367673, 2974474 | email: bthrai@bharatstesthouse.com

(1) The above results are related only to the Tests/Calibration performed on the product received. Endorsement of product is neither inferred nor implied. (2) This report is not to be reproduced wholly or in part & forbidden to be used as an evidence in the court law & ought not to be used in any advertising media without our special permission in writing. (3) Samples will be destroyed after 15 & 30 days from the date of reporting unless otherwise specified. (4) Total liability of our Test House is limited to the invoice amount. (5) Report refers to the product received by Bharat Test House Pvt. Ltd. Unless mentioned otherwise.

**ISO 9001:2008, ISO 14001:2004 & OHSAS 18001 CERTIFIED LAB**

**Product information:** Specification of Equipment under Test (EUT) provided by Manufacturer

Parameter	Value
1) Rating	
a) Maximum Output power	1400 W
b) DC Voltage range	22V – 55V
c) DC Current range	40A
d) AC Voltage range	(212 – 264) V
e) Frequency range	(48 – 52) Hz
f) AC Current Limits	6.09A
g) Efficiency	95%
h) Voltage and frequency trip settings (magnitude and timigs)	--
i) Other software settings	--
j) Firmware version	--
2) Others	
a) Displays	--
b) Temperature Range	-25°C to 60°C
c) Humidity	--
d) Size (LxBxH)	32.2 cm x 27.8 cm x 6.1 cm
e) Weight	7.5 Kg

**i) Efficiency test as per the requirements of Cl. No. 4.6, 5.1, 5.2 & 5.3.**

Table 1: Efficiency recording sheet								
Input voltage:		Vmin. = 37.7 V						
Sl. No.	Testing, load, % of rated VA (Resistive load)	5%	10%	25%	50%	75%	100%	120%
1	Input DC Voltage (V)	-	37.7	37.8	38.1	37.9	37.8	-
2	Input DC Current (A)	-	4.03	10.03	19.89	29.91	39.85	-
3	Input DC Power (W)	-	151.9	379.1	757.8	1133.6	1506.3	-
4	Output RMS Voltage (V)	-	230.22	230.24	230.25	230.28	230.26	-
5	Output RMS Current (A)	-	0.65	1.51	3.11	4.65	6.19	-
6	Output AC Power (W)	-	136.1	340.7	708.9	1060.1	1411.1	-
7	Power Efficiency (%)	-	89.6	89.9	93.5	93.5	93.7	-
8	Power factor	-	0.91	0.98	0.99	0.99	0.99	-
9	Voltage THD (%)	-	0.04	0.04	0.04	0.05	0.06	-
10	Current THD (%)	-	19.13	7.68	4.15	2.89	2.61	-
11	Input Energy (Wh)	-	2.53	6.32	12.63	18.89	25.1	-
12	Output Energy (Wh)	-	2.27	5.68	11.82	17.67	23.52	-
13	Energy Efficiency (%)	-	89.7	89.9	93.6	93.5	93.7	-

Supplementary Information: - Grid-connected EUT.  
 - 120% load was excluded due to limitation of power conditioning unit.  
 - Energy averaged over a period of 1 minute, Wh.



BTHPL/7.2/01

**BHARAT TEST HOUSE PVT. LTD.**

 1474, HSIIDC Industrial Estate, Rai, Distt-Sonepat, Haryana-131001  
 Tel: 0130-2367673, 2974474 | email: bthrai@bharattesthouse.com

(1) The above results are related only to the Tests/Calibration performed on the product received. Endorsement of product is neither inferred nor implied. (2) This report is not to be reproduced wholly or in part & forbidden to be used as an evidence in the court law & ought not to be used in any advertising media without our special permission in writing. (3) Samples will be destroyed after 15 & 30 days from the date of reporting unless otherwise specified. (4) Total liability of our Test House is limited to the invoice amount. (5) Report refers to the product received by Bharat Test House Pvt. Ltd. Unless mentioned otherwise.

**ISO 9001:2008, ISO 14001:2004 & OHSAS 18001 CERTIFIED LAB**

**Table 2: Efficiency recording sheet**

Input voltage:		Vnom. = 48.8 V						
Sl. No.	Testing, load, % of rated VA (Resistive load)	5%	10%	25%	50%	75%	100%	120%
1	Input DC Voltage (V)	-	48.2	48.1	48.6	47.9	48.9	-
2	Input DC Current (A)	-	3.15	7.81	15.58	23.81	30.81	-
3	Input DC Power (W)	-	151.8	375.7	757.2	1140.5	1506.6	-
4	Output RMS Voltage (V)	-	230.23	230.24	230.23	230.27	230.25	-
5	Output RMS Current (A)	-	0.66	1.53	3.14	4.84	6.18	-
6	Output AC Power (W)	-	138.3	345.2	715.7	1103.4	1408.7	-
7	Power Efficiency (%)	-	91.1	91.9	94.5	96.7	93.5	-
8	Power factor	-	0.91	0.98	0.99	0.99	0.99	-
9	Voltage THD (%)	-	0.04	0.04	0.04	0.05	0.06	-
10	Current THD (%)	-	20.74	7.67	3.86	2.48	2.54	-
11	Input Energy (Wh)	-	2.53	6.26	12.62	19.01	25.11	-
12	Output Energy (Wh)	-	2.31	5.75	11.93	18.39	23.48	-
13	Energy Efficiency (%)	-	91.3	91.8	94.5	96.7	93.5	-

Supplementary Information: - Grid-connected EUT.  
 - 120% load was excluded due to limitation of power conditioning unit.  
 - Energy averaged over a period of 1 minute, Wh.

**Table 3: Efficiency recording sheet**

Input voltage:		Vmax. = 54 V						
Sl. No.	Testing, load, % of rated VA (Resistive load)	5%	10%	25%	50%	75%	100%	120%
1	Input DC Voltage (V)	-	-	53.9	54.9	54.8	54.2	-
2	Input DC Current (A)	-	-	7.16	13.89	20.81	27.85	-
3	Input DC Power (W)	-	-	385.9	762.6	1140.4	1509.4	-
4	Output RMS Voltage (V)	-	-	230.23	230.24	230.27	230.28	-
5	Output RMS Current (A)	-	-	1.59	3.19	4.78	6.21	-
6	Output AC Power (W)	-	-	358.7	727.1	1089.7	1415.7	-
7	Power Efficiency (%)	-	-	92.9	95.3	95.5	93.8	-
8	Power factor	-	-	0.98	0.99	0.99	0.99	-
9	Voltage THD (%)	-	-	0.04	0.04	0.05	0.06	-
10	Current THD (%)	-	-	6.93	3.11	2.27	2.45	-
11	Input Energy (Wh)	-	-	6.43	12.71	19	25.16	-
12	Output Energy (Wh)	-	-	5.97	12.12	18.16	23.59	-
13	Energy Efficiency (%)	-	-	92.8	95.3	95.6	93.7	-

Supplementary Information: - Grid-connected EUT.  
 - 120% and 10% load was excluded due to limitation of power conditioning unit.  
 - Energy averaged over a period of 1 minute, Wh.

ii) Cl. 5.4 - Efficiency tolerance of power conditioner at rated condition (%) = -1.22%



BTHPL/7.2/01

**BHARAT TEST HOUSE PVT. LTD.**

 1474, HSIIDC Industrial Estate, Rai, Distt-Sonepat, Haryana-131001  
 Tel: 0130-2367673, 2974474 | email: bthrai@bharattesthouse.com

(1) The above results are related only to the Tests/Calibration performed on the product received. Endorsement of product is neither inferred nor implied. (2) This report is not to be reproduced wholly or in part & forbidden to be used as an evidence in the court law & ought not to be used in any advertising media without our special permission in writing. (3) Samples will be destroyed after 15 & 30 days from the date of reporting unless otherwise specified. (4) Total liability of our Test House is limited to the invoice amount. (5) Report refers to the product received by Bharat Test House Pvt. Ltd. Unless mentioned otherwise.

**ISO 9001:2008, ISO 14001:2004 & OHSAS 18001 CERTIFIED LAB**

## iii) Cl. No. 6 – Efficiency test circuit:




Figure 1b – Utility-Interactive type

Figure 1.b: Test circuit diagram for measuring by considering the power conditioner is utility-interactive type – where

PC	Power conditioner	L	Load
PS	Variable voltage-current DC power supply	F	Frequency meter
A1	DC ammeter	V1	DC voltmeter
A2	AC or DC ammeter	V2	AC or DC voltmeter
W1	DC wattmeter	PF	Power factor meter
W2	AC to DC wattmeter		

## iv) Cl. 7 - Loss measurements

Table 4: Cl. 7.1 - No load loss measurement				
Input DC Voltage, V dc		Input DC Current, A	No load loss, W	Energy averaged over a period of 1 minute, Wh
V min	37.7 V	0.03	1.13	0.019
V nominal	48.8 V	0.03	1.46	0.024
90% of V <sub>max</sub>	54 V	0.03	1.62	0.027
Supplementary information: The power conditioner is a "utility-interactive type"				

Table 5: Cl. 7.2 - Standby loss measurement	
Provision for standby mode is not provided with the Inverter.	
Supplementary information: The power conditioner is a "utility-interactive type"	


**TEST SUMMARY**

Efficiency measurement test results							
Serial No: -1114A4050046 Model: MS1500		Temperature: 25°C±2°C Output Voltage: 230Vac, 50Hz					
Input Voltage (V dc)		Power Level					
		10%	25%	50%	75%	100%	120%
		140W	350W	700W	1050W	1400W	1680W
		η (%)					
		Rated output efficiency and partial output efficiency					
Vmin	37.7 V	89.6	89.9	93.5	93.5	93.7	
Vnominal	48.8 V	91.1	91.9	94.5	96.7	93.5	
Vmax (90% of max. V dc)	54 V	-	92.9	95.3	95.5	93.8	


BIHPL/7.2/01

**PHOTOGRAPHS**

**Front View**



**Back View**



.....End of Report.....

BTHPL/7.2/01

**BHARAT TEST HOUSE PVT. LTD.**

1474, HSIIDC Industrial Estate, Rai, Distt-Sonepat, Haryana-131001  
Tel: 0130-2367673, 2974474 | email: bthrai@bharatstesthouse.com

(1)The above results are related only to the Tests/Calibration performed on the product received. Endorsement of product is neither inferred nor implied. (2) This report is not to be reproduced wholly or in part & forbidden to be used as an evidence in the court law & ought not to be used in any advertising media without our special permission in writing. (3) Samples will be destroyed after 15 & 30 days from the date of reporting unless otherwise specified. (4) Total liability of our Test House is limited to the invoice amount. (5) Report refers to the product received by Bharat Test House Pvt. Ltd. Unless mentioned otherwise.

**ISO 9001:2008, ISO 14001:2004 & OHSAS 18001 CERTIFIED LAB**